



## **QT603**

## Quantec network splitter



## Overview

An essential wiring/installation aid for C-TEC'sQuantec Addressable Call System.

Helps protect against open and short circuit faults and reduces the risk of volt drop.

Includes one input and one output connection for Quantec's 'Spine' wiring (typically 1.5-2.5mm T&E) and sixfused 400mA 'limb' connections for the wiring of individual circuits containing Quantec's fielddevices (typically 4 core stranded security cable).

At least one QT803 is required perQuantec system (the more you use, the easier it will beto program and fault-find).

Install one QT603 per corridor junction (locate at the end of the corridor nearest to the Quantec Controller). If the corridor is longer than 50m, install the splitter in the centre of the corridor to reduce wiring runs.

Mounts on a standard 25mm UK double gang back box.

'Power' and 'Fault' indicators.

Max.60 addressable devices per QT603.

## More Information

Quantec utilises a unique data protocol that works down two wires andamaximum of 255 addressable devices can be connected to a Quantec Controller (dependent on network topology). Addressable devices require 2 network connections. Slave devices such as slave ceiling pullsandslave overdoor lights connect to Quantec via a master call point, master ceiling receiver, monitoring point or universal programming device using 2, 3 or 4 cores of stranded security cable. Wiring must bemade in a 'Spine' and 'Limb' configuration using one or more QT803 network splitters. This allows the use of ordinary unscreened cable which simplifies installation, fault-finding and commissioning. SPINE WIRING

Wire Spines in 1.5mm2 or 2.5mm2 T&E

For a typically loaded system, the following spine lengths apply:

Max. length for a single spine using 1.5 mm2 cable = 150 m

Max. length for a single spine using 2.5 mm2 cable = 250 m

Max. length of all spines + limbs = 750 m.DO NOT wire any devices to the spine other than network splitters.

LIMB WIRING

Wire Limbs in a minimum of 4 core cable (7/0.2 mm2 strand) twisted into one pair to reduce voltage drop.

No. of Limbs per Splitter = 6; Max. length per limb = 60 metres.

Max. number of addressable devices per limb = 15; Max. number of addressable devices per Splitter = 60.

If possible, distribute devices at equal distances along the length of the limb.

The Quantec Controller can be located anywhere on the network, although it is normal practice to install it centrally to reduce wiring runs, ideally in a manager or supervisor's office. Distribute Splitters evenly throughout the site and locate at an accessible height.

For more information on these products, please contact us:



T: 00353 47 86274 / 00353 47 86663

E: Sales@irishsafetysystems.ie